

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing



Toll Free 800-273-8901
 Telephone 908-688-8900
 Fax 908-688-8966
 Email: info@gsllabs.com
 Internet: www.gsllabs.com

Main Lab
 410 Hillside Avenue
 Hillside, New Jersey 07205
 NJDEP Lab Cert. #20044

Mathew Klein, M.S., Founder (1916-1996)
 Harvey Klein, M.S., Laboratory Director
 Jordan B. Klein, B.A., Exec. Vice President
 Sharon Ercoliani, B.A., Laboratory Manager

Jersey Shore Lab
 54 Main Street
 Waretown, New Jersey 08758
 NJDEP Lab Cert. #15037

Report of Bathing Water Analysis

Lyndhurst High School
 C/O Lyndhurst Parks and Recreation Department
 250 Cleveland Ave.
 Lyndhurst NJ 07071
 ATT: Tom Cafaro

CLIENT #: L3181ID

REPORT #: 38071801118.00

DATE SAMPLED: 7/18/2018 9:45

Location	Pool		
	Results	Conforms	Analyzed
Total Coliform	Absent	Yes	7/18/2018 15:31
Heterotrophic Plate Count	5	Yes	7/18/2018 15:31
pH	7.2	Yes	
Free Chlorine	1.5	Yes	

Site Location:
 Lyndhurst High School
 400 Weart Ave.
 Lyndhurst NJ 07071

This sample conforms to State Public Recreational Bathing Standards for the above analyses.

Comments	Sample analyzed at Main Lab - NJDEP #20044
----------	--

COPY SENT TO HEALTH AUTHORITY: LYNDHURST

Conforms (Yes/No): Designates whether results conform to State Standards for public recreational bathing water quality.

- pH results in standard units. pH shall be 7.2 to 7.8, ideally 7.4 to 7.6. When pH is reported as 6.8 the pH is 6.8 or below. When pH is reported as 8.2 the pH is 8.2 or above. Method - phenol red test kit.
- Chlorine or bromine results in parts per million, ppm. Free Chlorine shall be 1.0 to 10.0 in swimming pools & 2.0 to 10.0 in whirlpools, hot tubs or spas. Bromine shall be 2.0 to 10.0 in swimming pools & whirlpools, hot tubs or spas. Method - DPD test kit.
- Heterotrophic Plate Count results in organisms per ml. HPC shall not exceed 200 organisms per ml.
- Total coliform in swimming pools, *Pseudomonas aeruginosa* in whirlpools, hot tubs or spas, *E. coli* in beaches, enterococcus in marine waters. Results in organisms per 100 ml. Total coliform and *Pseudomonas aeruginosa* results shall be absent (less than 1 organism) per 100 ml. *E. coli* results shall not exceed 320 organisms per 100 ml. Enterococcus results shall not exceed 104 organisms per 100ml.

Methods: HPC – SM 9215B, *Pseudomonas aeruginosa* - Pseudalert, *E. coli* – USEPA 1603, enterococcus - USEPA 1600, total coliform - Colilert-04.

For the latest public recreational bathing water information and a link to the New Jersey State Sanitary Code regarding Public Recreational Bathing, N.J.A.C. 8:26, visit our website at www.gsllabs.com/pools.html.