

LYNDHURST DEPARTMENT OF FIRE SAFETY

253 Stuyvesant Avenue Lyndhurst, NJ 07071 201-933-3073

Robert Ferrara
Fire Official

12/4/203/10/202218

To: Lyndhurst Planning Board

Dear Planning Board

RECEIVED
MAR 10 2022
LYNDHURST
PLANNING & ZONING DEPT.

The Fire Department reviewed the site plan for 316 Valley-brook Ave. with the installation of charging stations for electric vehicles, It is our opinion that no chargers be placed under the structure or any enclosed parking area. The Fire Department would like to see all, EV units outside the building, this is for firefighting procedures.

Electric Vehicles are extremely difficult to extinguish and causes an exposure problem if they catch fire when charging. For this reason, we feel it is in the best interest to move the charging stations to the outside of the building.

Thank you

Robert Ferrara

Fire Official